

## SUMMARY DATA SHEET: VOC Engineered Hardwood Timber Flooring Date: July 2020

### 1 COMPANY DETAILS

Company: Homemirus Pty Ltd trading as Preference Floors  
Address: 32 Britton Street Smithfield NSW 2164  
Telephone: 02 9738 1188  
Facsimile: 02 9738 1199

### 2 PRODUCT IDENTIFICATION

**Engineered Hardwood Timber Mixed Species**, nominal sizes, 135 > 190mm x 12 > 14mm  
**Covers, 12 & 14mm - European Oak & Australian Timber Blackbutt and Spotted Gum**

### 3 HEALTH HAZARD DATA

Formaldehyde Emission from newly produced Engineered Hardwood Timber Flooring

### 4 RESULT AND CONCLUSIONS

**Test Method: Standard pr-ENV 717-1**

We can confirm test results of; **0.068 & 0.080 which provides an outcome of <E1**. This level falls below **the E1 limits, < 0.124mg/m<sup>3</sup> ( 0.1ppm)** as recommended by the World Health Organisation (WHO).

**Disclaimer:** Homemirus Pty Ltd trading as Preference Floors has used its reasonable endeavours to ensure the accuracy and reliability of the information contained herein and, to the extent permitted by law, will not be liable for any inaccuracies, omissions, or errors in this information nor for any actions taken in reliance on this information. Products must be installed in accordance with relevant installation recommendations and industry best practices.

© Homemirus Pty Ltd trading as Preference Floors. Date of publication July 2020.

[www.preferencefloors.com.au](http://www.preferencefloors.com.au)

#### Adelaide (SA)

t +61 8 8262 2774  
sa@preferencefloors.com.au

#### Brisbane (QLD)

t +61 7 3875 1688  
qld@preferencefloors.com.au

#### Melbourne (VIC)

t +61 3 9794 5111  
vic@preferencefloors.com.au

#### Perth (WA)

t +61 8 9471 7785  
wa@preferencefloors.com.au

#### Sydney (NSW)

t +61 2 9738 1188  
sales@preferencefloors.com.au