

Fire & Smoke Test Certificate

Thursday, 22nd February 2024

Supplier: Floor Distributors Pty Ltd (719 The Horsley Drive, SMITHFIELD, NSW 2164, Australia).

Sample Description: Viva Luxury Vinyl Plank Flooring.

Nominal Mass per unit area: 7.5 Kg/m²

Nominal Thickness: 4.5 mm

Date of samples arrived: 02/02/2024.

Date Tested: 21 February 2024 (Tested by Laboratory – NATA Accreditation 1356)

Test Method: AS/ISO 9239-1:2003 Reaction to Fire Tests for Floorings:
Determination of the Burning Behaviour using a Radiant Heat Source.

Test Results:

CHF Values	1	2	3	Mean	
Length	10.7	-	-	-	kW/m ²
Width	10.5	10.5	10.3	10.4	kW/m ²
Smoke Value	1	2	3	Mean	
Length	99	-	-	-	%.min
Width	101	84	91	92	%.min

Observation:

Blistering: Yes

Sample was conditioned in accordance with BSEN 13238:2010 at temperature of $23\pm 2^{\circ}\text{C}$ and relative humidity of $50\pm 5\%$ for a minimum of 48 hrs prior to testing.

Each specimen was clamped to a substrate of 6mm thick Fibre reinforced cement board prior to testing.

HF30 not reported as flame out time occurred before 30 minutes.

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test, they are not to be sole criterion for assessing the potential fire hazard of the product in use.


Results in accordance with section 8.4 have not been included in the report. They are available upon request.



Photo of tested product



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc (Biotech)
Senior Consultant



Dr. Tuan Duong
PhD, B. Eng. (Chemical)
Senior Consultant

Issue date 22/2/2024

Expiry date: 22/2/2029

P24020011